



Note 1: Both EPO systems MUST power from same line to prevent phase shorting.
Note 2: Relay R1 has 120VAC coil. Relay R2 has low voltage coil.
Note 3: Assumed that SiteIO module can sense open/grounded contacts.

Drawn: Kwarcianny		
Title Fermilab GCC Computer Room Emergency Power Off System		
Size B	Document Number CD-doc-3209	Rev A
Date: Monday, March 08, 2010	Sheet 1	of 1